

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016457
DATE: 01/06/2025
CERTIFICATION PROGRAM: Structural
COMPANY: SLEEK
CODE: 3114-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namincertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
SLEEK (Shanghai) Intelligent System Co., Ltd. No. 61, Lane 2329, Jiasong Middle Road, Qingpu District, Shanghai, China 310118	Series "SLEEK 83" Aluminum Tilt and Turn Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1200mm(47.24") H-1800mm(70.87") Vent: W-1172mm(46.14") H-1772mm(69.76") DLO: W-1109mm(43.66") H-1709mm(67.28")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19	Class CW-PG50 1200 x 1800 (47 x 71)-DAW Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: 240924012SHF-003
Expiration Date: **November 30, 2028**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023